



KINGDOM OF CAMBODIA  
NATION RELIGION KING

ELECTRICITÉ DU CAMBODGE

Ref: 4935 EDC.PD

Phnom Penh, 01, July, 2024

**Attention : Prospective Bidders**  
**Project : German Financial Cooperation with Cambodia.**  
**Energy Efficiency in Rural Power Supply BMZ-No. 2018.68.207**  
**Subject : Addendum No. 2 for Package A “Substations and OHL Works”**  
**Reference : Bidding Document of Package A (IFB No: KfW-EDC-P1-2024-A)**

**ADDENDUM No. 2**

**Dear Sir/Madam,**

We, Electricité du Cambodge (EDC), here issue an Addendum No. 2 for Package A “Substations and OHL Works” for the Project of Energy Efficiency in Rural Power Supply BMZ-No. 2018.68.207 as enclosed attachment.

For our records, we would greatly appreciate your acknowledgement of receipt of this letter and a copy sent to us at your earliest convenience.

Sincerely yours,



**Dr. Praing Chulasa**  
Royal Government of Cambodia Delegate *u*  
in charge as Managing Director *And Rula*

To: **Electricité du Cambodge**  
We acknowledge receipt of above document, Addendum No. 2  
Name of Company: .....  
Signature of Representative: .....

*Handwritten initials*

**KINGDOM OF CAMBODIA  
NATION RELIGION KING**

**ELECTRICITE DU CAMBODGE**

**German Financial Cooperation  
with Cambodia**

**Project: Energy Efficiency in Rural  
Power Supply  
ADDENDUM No 2**

**for**

**Procurement of Package A: Substations and OHL Works**

Design, Engineering, Procurement and Construction of Complete:

115 / 22 kV Grid Substation in South Siem Reap (between Pouk and East Siem Reap S/S).

115 / 22 kV Grid Substation in Kralanh district of Siem Reap province (near Siem Reap/ Banteay Meanchey border between Banteay Meanchey and Pouk S/S).

115 kV Overhead transmission line in Siem Reap Province between South Siem Reap Substation and new GIS Phase II Substation.

**Client:** Electricité du Cambodge

**Country:** Kingdom of Cambodia

**Project:** Energy Efficiency in Rural Power Supply

**KFW financing No:** BMZ-No.:2018.68.207

**KFW-Procurement No:** 510544

**Project Implementation Consultants (PIC):** Electricite de France (EDF)

This addendum modifies only the following sections as detailed. (All the other parts of the tender documents remain unchanged)

No	Volume/Section	Clause	Original bid	Addendum 2	Attachment
1	Part 2 / Section VII – 3- SS drawings	GLD of South Siem Reap SS	Location of Future 115kV bays.	The new future bays are highlighted and identified in black.	<b>Replace</b> Drawing No EDC-EDF-SS-002 rev B by Drawing No EDC-EDF-SS-002 rev C in the attachment 1
2	Part 1 / section IV – Schedule of prices for OHL & protected Excel sheet for Package A -115 KV Overhead Transmission line– Schedule 4C	Item 4C7.1  Item 4C7.7.2	Quantities of “pole foundation type A” 4.2  Quantity of “Check survey, flat plan drawing, plan and profile drawing and tower location spotting” 0	Quantities of “pole foundations type A” to read 14 instead of 4.2 (Item 4C7.1) - Unit to be Foundation  Quantity of “Check survey, flat plan drawing, plan and profile drawing and tower location spotting” to read 4 Km instead of 0. (Item 4C7.7.2)  (Quantities rectified in schedule of prices included in the addendum No 2)	<b>Replace</b> Excel file PROTECTED_Pack A-115kV Overhead Transmission Line_BID-Mod 15112023 by PROTECTED_Pack A-115kV Overhead Transmission Line_BID- Rev 1 in the attachment 2  Part I- Section IV – Page 109/119 – Item 4C7.1 and Item 4C7.7.2 in the attachment 3

3	Part 1 / section IV – Schedule of prices for Kralanh SS & protected Excel sheet for package A BoQ for 115-22 Kv Kralanh SS – Schedule 1, 2 and 4	Schedule 1, 2 and 4: Add items 409 and 410	Item No. 400: Control protection equipment	Add the following items in Schedule 1, 2 and 4: 409: 115kV Bus Coupler control panel 410: 115kV Bus Coupler protection relay panels  (Quantities rectified in schedule of prices included in the addendum No 2)	<b>Replace</b> Excel file PROTECTED_Pack A- rev 4-BOQ for 115-22 kv Kralanh SS by PROTECTED_Pack A- rev 5-BOQ for 115-22 kv Kralanh SS in the attachment 4  Part I- Section IV – Page 55/119 – Add item 409 and 410 Page 59/119 – Add item 409 and 410 Page 65/119 – Add item 409 and 410 In the attachment 5
4	Part 1 / section IV – Schedule of prices for South Siem Reap SS & protected Excel sheet for package A BoQ for 115-22 Kv South Siem Reap SS – Schedule 1, 2 and 4	Schedule 1, 2 and 4: Add items 409 and 410	Item No. 400: Control protection equipment	Add the following items in Schedule 1, 2 and 4: 409: 115kV Bus Coupler control panel 410: 115kV Bus Coupler protection relay panels  (Quantities rectified in schedule of prices included in the addendum No 2)	<b>Replace</b> Excel file PROTECTED_Pack A- rev 4-BOQ for 115-22 kv South Siem Reap SS by PROTECTED_Pack A- rev 5-BOQ for 115-22 kv South Siem Reap SS in the attachment 6  Part I - Section IV – Page 75/119 – Add item 409 and 410 Page 79/119 – Add item 409 and 410 Page 84/119 – Add item 409 and 410 In the attachment 7

5	Bid documents: IFB, section III, section VII-1 SS ; Section VII- 4 OHL, Section IX,		The execution period of 18 months	Extension of execution period from 18 to 24 months for Package A	N/A
6	Section III evaluation and qualification criteria	Table 2 – Clause 4.2 (a) requirement (ii)		Replace “Out of the above contracts, At least one of them shall have been executed in the Southeast Asia or Cambodia and at least one contract must be completed within 18 months from the commencement date.” By Out of the above contracts, at least one of them shall have been executed in the Southeast Asia or Cambodia and at least one contract must be completed within 24 months from the commencement date.	N/A
7	Part 1 / section IV – Schedule of prices for Kralanh SS & protected Excel sheet for package A BoQ for 115-22 Kv Kralanh SS – Schedule 1, 2 and 4	Schedule 1, 2 and 4: remove item 702	Item 702: Fiber Optical Approach Cable (OCAP) and accessories	Delete item 702	<b>Replace</b> Excel file PROTECTED_Pack A- rev 4- BOQ for 115-22 kv Kralanh SS by PROTECTED_Pack A- rev 5- BOQ for 115-22 kv Kralanh SS in the attachment 4

				(Quantities rectified in schedule of prices included in the addendum No 2)	Part I- Section IV – Page 56/119 – Delete item 702 Page 60/119 – Delete item 702 Page 66/119 Delete item 702 In the attachment 8
8	Procurement ID	KfW Procurement No.	505038	510544	N/A
9	Section II, ITB 23.1: The deadline for bid submission	Bid Submission Time	16 <sup>th</sup> July 2024 10:00 am Cambodia Standard Time	23 <sup>rd</sup> July 2024 10:00 am Cambodia Standard Time	N/A
	Section II, ITB 26.1: The bid opening	Bid Opening Time	16 <sup>th</sup> July 2024 10:30 am Cambodia Standard Time	23 <sup>rd</sup> July 2024 10:30 am Cambodia Standard Time	N/A

Attachment refers to the scan of QR code below:

